


Calibration of ABB regulation valve:

Dismount the front cover and press on the "F" push button for 5 sec.



The menu "ADJ_ROT" will pop up



Press the "F" push button for 3 sec. and the calibration sequence will start



Wait until it is finished. It may take a few minutes.



Adjust the visual indicator according to the valve position. It can easily be taken off and mounted correctly.

